2015 SEATTLE FIRE CODE

Activities Requiring a Permit

To download a permit application, write down the Permit Search Category of the desired permit and then use the online Permit Search to download the application.

If you are not sure whether or not you are required to obtain a permit, please call the Seattle Fire Department Permit Unit for assistance at (206) 386-1450. We are open Monday through Friday, 8:00 a.m. to 4:30 p.m.

Activity or operation	Permit required:			Permit Search Category
Aerosol products	To manufacture, store or handle an aggregate quantity of Level 2 or Level 3 aerosol products in excess of 500 pounds (227 kg) net weight. (SFC 105.6.1)			Hazardous Materials
Amusement Buildings	To operate a special amusemer See also Special Events.	nt building. (SFC 105.6	.2)	Special Events & Assembly Occupancies
Assembly occupancy	To operate an assembly occupa more. (SFC 105.6.41). See als Temporary Assembly Event.			Special Events & Assembly Occupancies
Aviation facilities	To use a Group H or Group S o and aircraft fuel-servicing vehicl		ervicing or repair	Special Occupancy Uses
Bonfires	To ignite a bonfire. (SFC 105.6.	4)		Special Events & Assembly Occupancies
Canopies, tents	To erect a temporary membrane structure or a tent having an area in excess of 400 square feet, or a canopy in excess of 700 square feet, with certain conditions. (SFC 105.7.18) See also Special Events.			Special Events & Assembly Occupancies
Carnivals and fairs	To conduct a carnival or fair tha Seattle Special Events permit. (Special Events & Assembly Occupancies
Cellulose nitrate film	To store, handle or use cellulos (SFC 105.6.7)	e nitrate film in a Group	A occupancy.	Hazardous Materials
Combustible dust- producing operation	To operate a grain elevator, flour starch mill, feed mill, or a plant pulverizing aluminum, coal, cocoa, magnesium, spices or sugar, or other operations producing combustible dusts as defined in SFC Chapter 2. (SFC 105.6.8)			Miscellaneous Operations
Combustible fibers	To store or handle combustible feet (2.8 m3). (SFC 105.6.9)	fibers in quantities grea	ater than 100 cubic	Miscellaneous Operations
Combustible material storage	To store in any building or upon any premises in excess of 2500 cubic feet (71 m3) gross volume of Class III or higher hazard combustible material. (SFC 105.6.10, hazard list from SFC 3203.4)		Miscellaneous Operations	
Compressed gases	To store, use or handle at normal temperature and pressure (NTP) compressed gases in excess of the amounts listed:			Hazardous Materials
	Type of Gas	Gas Amount (cubic feet at NTP)		
	Corrosive 200			
	Flammable (except cryogenic fluids and LP-gas)	200		
	Highly toxic, toxic, or pyrophoric	Any amount		
	Inert and simple asphyxiant 6,000			
	Oxidizing (including oxygen)	ng oxygen) 504		
	2. When compressed gases in use or storage exceed the amounts listed in the table above, a construction permit is required to install, repair damage to, abandon, remove, place temporarily out of service, or close or substantially modify a compressed gas system. (SFC 105.6.11 & 105.7.3)			
Covered mall building	For the: 1. Placement of retail fixtures and displays, concession equipment, displays of highly combustible goods and similar items in the mall. 2. Display of liquid- or gas-fired equipment in the mall. 3. Use of open-flame or flame-producing equipment in the mall. (SFC 105.6.12) See also Special Events.			Special Events & Assembly Occupancies
Cryogenic fluids	To produce, store, transport on site, use, handle or dispense cryogenic fluids in excess of the amounts listed: (SFC 105.6.13)			Hazardous Materials
	Type of cryogenic fluid	Inside a building (gallons)	Outside a building (gallons)	
	1	More than 1	60	
	Flammable			
	Inert	60	500	
				

Cutting and welding	See hot work operations. (SFC 105.6.27)		Hot Work Operations	
Dry cleaning plants	To engage in the business or dry cleaning or to change to a more hazardous cleaning solvent used in existing dry cleaning equipment. (SFC 105.6.15)			Special Occupancy Uses
Exhibits and trade shows	To operate exhibits and trade shows. (SFC 105.6.16) See also Special Events.		Special Events & Assembly Occupancies	
Explosives	The storage, handling sale or use of any quantity of explosive, explosive material, fireworks, or pyrotechnic special effects within the scope of SFC Chapter 56. The manufacture of explosives is prohibited. (SFC 105.6.17)		Hazardous Materials	
Fire hydrants and valves	To use or operate fire hydrants or valves intended for fire suppression purposes which are installed on water systems and accessible to a fire apparatus access road that is open to or generally used by the public. Exception: Authorized employees of the water company that supplies the system or the fire department. (SFC 105.6.17)		Contact Seattle Public Utilities	
Flammable and combustible			ombustible liquid pipeline within	Flammable and Combustible Liquids
liquids (see also Food vending)	 To remove Cl tank used for approved, stapurposes. To operate, ir tanks, plants, distilleries and liquids are proused. 	Class I or Class II liquids from an underground storage or fueling motor vehicles by any means other than the stationary on-site pumps normally used for dispensing install, construct or alter tank vehicles, equipment, is, terminals, wells, fuel-dispensing stations, refineries, and similar facilities where flammable and combustible produced, processed, transported, stored, dispensed or		
	To place temporarily out of service (for more than 90 days) an underground, protected above-ground or above-ground flammable or combustible liquid tank.			
	5. To install, alter, remove, abandon or otherwise dispose of a flammable or combustible liquid tank.6. To change the contents stored in a flammable or combustible liquid tank to a material which poses a greater hazard than that for which			
	the tank was designed and constructed.7. To manufacture, process, blend or refine flammable or combustible liquids.			
	To engage in the dispensing of liquid fuels into the fuel tanks of motor vehicles at commercial, industrial, governmental or manufacturing establishments.			
	 To utilize a site for the dispensing of liquid fuels from tank vehicles into the fuel tanks of motor vehicles at commercial, industrial, governmental or manufacturing establishments. To engage in the business of removing, abandoning or otherwise disposing of residential heating oil tanks. To store, handle or use flammable or combustible liquids in excess of the quantities listed in the following table: (SFC 105.6.19 & 105.7.8) 			
	or the quantities in	•	torage or Use	
	Class of Liquid	Inside a Building (gallons)	Outside a Building (gallons)	
	Class I	5	10	
	Class II	25	60	
	Class III-A Class III-B	25 any amount for t	60 fueling motor vehicles or where	
Floor finishing	connected to fuel-burning equipment To conduct floor finishing or surfacing operations exceeding 350 square		Miscellaneous Operations	
Food vending	feet using Class I or Class II liquids. (SFC 105.6.20) To use liquefied petroleum gas (LPG) also known as propane, and/or solid fuel like charcoal briquettes, for the purpose of food vending and/or area heating. (SFC 105.6.31)		Special Events & Assembly Occupancies	
Fruit and crop ripening	To operate a fruit- or crop-ripening facility or conduct a fruit-ripening process using ethylene gas. (SFC 105.6.21)		Miscellaneous Operations	
Fumigation and insecticidal fogging	To operate a business of fumigation or thermal insecticidal fogging and to maintain a room, vault, freight container, or chamber in which a toxic or flammable fumigant is used. (SFC 105.6.22)		Miscellaneous Operations	
Hazardous materials	To install, repair damage to, abandon, remove, place temporarily out of service, or close or substantially modify a storage facility or other area regulated by SFC Chapter 50. Exceptions: 1) Routine maintenance. 2) Emergency repair work. (SFC 105.7.10) To store, handle or use hazardous materials in excess of quantities listed in the Hazardous Material Permit Threshold Table. (SFC 105.6.23)		Hazardous Materials	
Hazardous	To stabilize potentially unstable (reactive) hazardous materials.		Hazardous Materials	
material stabilization	(SFC 105.6.24)			
	To store, handle or use hazardous production materials. (SFC 105.6.25)		Hazardous Materials	
HPM facilities	105.6.25)	ii use nazardous prod	delien materials. (et e	

Hot work operations	 To conduct hot work at public exhibitions and demonstrations. To use portable hot work equipment. Exceptions: No permit needed for approved self-contained torch assemblies with cylinders that comply with UL 147A, with maximum water capacity of 2.7 pounds, with no more than a further 2.7 pounds of aggregate water capacity in stored 	Hot Work Operations or Marine Operations (for hot work on vessels)
Industrial Ovens	 cylinders per control area. For fixed-site hot work equipment such as welding booths. For hot work conducted within a wildfire risk area. To apply roof coverings with the use of an open-flame device. To conduct hot work on storage tanks, piping and associated systems containing or previously containing flammable or combustible liquids, or other hazardous materials that could present a fire or explosion hazard. To conduct hot work on marine vessels. (SFC 105.6.27) To install and operate an industrial oven regulated by SFC Chapter 30. 	Miscellaneous Operations
Lumber yards and Woodworking	(SFC 105.6.28) To store or process lumber exceeding 100,000 board feet (8,333 ft ³). (SFC 105.6.29)	Special Occupancy Uses
Liquid or gas- fueled vehicles or equipment in	To display, operate or demonstrate liquid- or gas-fueled vehicles or equipment in assembly buildings. (SFC 105.6.30)	Special Events & Assembly Occupancies
LP-gas (propane)	 To store and use LP-gas. Exceptions: No permit needed for: Individual containers with a 500-gallon water capacity or less serving occupancies in Group R-3. A single LP-gas container having a water capacity not exceeding 48 pounds connected to a LP-gas grill unless located on or serving a public way or if used for commercial purposes. Storage of up to three forklift containers of no more than 104 pounds water capacity. To operate cargo tankers that transport LP-gas. To install or modify a LP-gas system. (SFC 105.6.31 & 105.7.8) 	Liquefied Petroleum Gases
LP-gas (propane) and solid fuel used for food vending – see Food Vending	For use with food vending or heating – see Food Vending	Liquefied Petroleum Gases
Magnesium	To melt, cast, heat treat or grind more than 10 pounds of magnesium. (SFC 105.6.32)	Hazardous Materials
Marine terminal and container freight stations	To handle or temporarily locate containers, tanks or cylinders of hazardous materials at marine terminals located within the Seattle city limits. (SFC 105.6.33)	Marine Operations
Membrane structure	To erect an air-supported temporary membrane structure or a tent having an area in excess of 400 square feet, or a canopy in excess of 700 square feet. (SFC 105.7.18) See also Special Events.	Special Events & Assembly Occupancies
Motor fuel- dispensing stations	To operate an automotive, marine or fleet motor fuel-dispensing station. (SFC 105.6.46)	Motor Vehicle Fueling
Open burning	Open burning is prohibited in the city of Seattle (SFC 105.6.36)	Special Events & Assembly Occupancies
Open flames and torches	To remove paint with a torch; or to use a torch or open-flame device in a wildfire risk area. (SFC 105.6.36)	Hot Work Operations
Open flames and candles, including flame effects	To use open flames or candles in connection with assembly areas, dining areas or restaurants or drinking establishments. Exception: a separate open flame and candle permit is not required at a facility with a valid place of assembly permit. (SFC 105.6.37)	Special Events & Assembly Occupancies
Organic coatings	For any organic-coating manufacturing operation producing more than 1 gallon of an organic coating in a day. (SFC 105.6.39)	Special Occupancy Uses
Outdoor Assembly Event	To operate an outdoor assembly event. (SFC 105.6.40)	Special Events & Assembly Occupancies
Private fire hydrants	For the removal from service, use or operation of private fire hydrants. Exception: A permit is not required for private industry with trained maintenance personnel, private fire brigade or fire departments to maintain, test and use private hydrants. (SFC 105.6.42)	Contact Seattle Public Utilities
Pyrotechnic special effects material	For the use and handling of pyrotechnic special effects material. (SFC 105.6.43) See also Special Events.	Special Events & Assembly Occupancies
Pyroxylin plastics	To store or handle more than 25 pounds of cellulose nitrate (pyroxylin) plastics for the assembly or manufacture of articles involving pyroxylin plastics. (SFC 105.6.44)	Hazardous Materials
Refrigeration equipment	To operate a mechanical refrigeration unit or system. Exception: No SFD permit needed for refrigeration systems that have a valid annual mechanical permit from the Department of Planning and Development. (SFC 105.6.45)	Building Systems and Maintenance
Repair garages	To operate a repair garage. (SFC 105.6.46)	Motor Vehicle Fueling, Repair and Wrecking
Rooftop heliports	To operate a rooftop heliport. (SFC 105.6.47)	Special Occupancy Uses

Spraying and dipping	 To conduct a spraying or dipping operation utilizing flammable or combustible liquids or to apply combustible powders regulated by SFC Chapter 24. To install or modify a spray room, dip tank or spray booth. (SFC 105.6.48 & 105.7.16) Note: A no-fee, operational permit is required for spraying 	Flammable and Combustible Liquids
	operations utilizing water-based paints in accordance with Chapter 24.	
Temporary assembly occupancy	To use any building or structure, or portion thereof, other than established Group A occupancies for assembly purposes with an occupant load of 50 or more. (SFC 105.6.50)	Special Events & Assembly Occupancies
Tents	To erect an air-supported temporary membrane structure or a tent having an area in excess of 400 square feet, or a canopy in excess of 700 square feet. (SFC 105.7.18) See also Special Events.	Special Events & Assembly Occupancies
Tire, scrap tire and tire byproduct storage	 To establish, conduct or maintain storage of tires, scrap tires, and tire byproducts that exceeds 2,500 cubic feet of total volume. To store tires and tire byproducts inside a building. (SFC 105.6.49) 	Miscellaneous Operations
Tire rebuilding plants	For the operation and maintenance of a tire-rebuilding plant. (SFC 105.6.52)	Special Occupancy Uses
Waste handling	To operate a waste-handling facility. (SFC 105.6.53)	Miscellaneous Operations
Wrecking yard	To operate a wrecking yard or junk yard. (SFC 105.6.53)	Motor Vehicle Fueling, Repair and Wrecking
Wood products	To store chips, hogged material, lumber or plywood in excess of 200 cubic feet. (SFC 105.6.52)	Miscellaneous Operations

Hazardous Materials Permit Threshold Table

	Demail is acquired for according	Developed an application for popula
Type of material	Permit is required for quantities in excess of:	Download an application for permit
Combustible liquids	See flammable and combustible	Level II blank permit app
Combactible liquids	liquids	<u>Lovor it blank portint app</u>
Corrosive Materials		
Gases	See compressed gases	Level II blank permit app
Liquids	55 gallons	
Solids	1,000 pounds	
Flammable materials		
Gases	See compressed gases	Level II blank permit app
Liquids	See flammable liquids	
Solids	100 pounds	
Highly toxic materials	Con compressed goods	Loyal II blank narmit ann
Gases Liquids	See compressed gases Any amount	Level II blank permit app
Solids	Any amount	
Oxidizing materials	7 and another	
Gases	See compressed gases	
Liquids	gaess gaess	
Class 4	Any amount	
Class 3	1 gallon	
Class 2	10 gallons	Level II blank permit app
Class 1	55 gallons	
Solids		
Class 4	Any amount	
Class 3	10 pounds	
Class 2 Class 1	100 pounds 500 pounds	
Organic peroxides	500 pourius	
Liquids		
Class	I Any amount	
Class		
Class I		
Class I'		Level II blank permit app
Class \	/ No permit required	
Solids		
Class		
Class		
Class I		
Class I'		
Pyrophoric materials	No permit required	
Gases	Any amount	Level II blank permit app
Liquids	Any amount	<u>Lovor ir blank pormit app</u>
Solids	Any amount	
Toxic materials		
Gases	See compressed gases	Level II blank permit app
Liquids	10 gallons	
Solids	100 pounds	
Unstable materials		
Liquids	Any amount	
Class 4	Any amount Any amount	
Class 3 Class 2	5 gallons	
Class 2 Class 1	10 gallons	Level II blank permit app
Solids	To gallono	Lover it blank permit app
Class 4	Any amount	
Class 3	Any amount	
Class 2	50 pounds	
Class 1	100 pounds	
Water-reactive materials		
Liquids		
Class 3	Any amount	
Class 2	5 gallons	Langt II blank a const
Class 1 Solids	55 gallons	Level II blank permit app
Solids Class 3	Any amount	
Class 3 Class 2	50 pounds	
Class 1	500 pounds	
	1 - >= F = =====	